



ADDENDUM No. 1

Tank Inspection and Repairs, ITB 24-02

Monday, January 22, 2024

The following change(s) to the above-referenced ITB have been made as designated below:

- | | |
|---|--|
| <input type="checkbox"/> Change of specification(s) | <input type="checkbox"/> Change of bid opening time and date |
| <input type="checkbox"/> Additional specification(s) | <input type="checkbox"/> Cancellation of bid |
| <input checked="" type="checkbox"/> Other- Additional Information | |

Additional Information - Q&A:

- Section 2.2B and E reference the FTPI 2007 standard for NDE and for the report format. Meanwhile, Section 2.3 B requires FRPI-8310 certified inspectors. Will the Owner accept NDE and report formatting based on FRPI-8310? **Yes**
- Section 2.2D specifies "Acoustic testing". Please clarify if this is meant to refer to percussive soundings or if this is meant to refer to Acoustic Emissions Testing? **Visual is good**
- If Section 2.2D is meant to refer to Acoustic Emissions Testing, will the Owner accept Advanced Ultrasonic Testing as an alternative NDE method? **Visual is good**
- Regardless of the meaning of Section 2.2D, would the Owner consider add-on pricing, quoted separately from the base bid, to perform Advanced Ultrasonic Testing? **No**
- What is the Owner's anticipated award date and start date for the project? **February 15th. TBD between awardee and CAW**
- What are the hours of operation at the site? **0730 to 1630**
- Does the Owner have any environmental, health or safety requirements that exceed OSHA requirements? If so, please explain. **No**

The above specifications by virtue of this addendum become a permanent addition to the above referenced ITB. Failure to return this signed addendum with your bid response may result in rejection of your bid.

If you have any questions, please contact Liz Tuck-Rowan at David.hindman@carkw.com or (501) 377-1315.

Company: _____

Signature: _____

Date: _____